



OFFICE OF PROCUREMENT SERVICES  
315 WEST MAIN STREET, SUITE 441  
PO BOX 7800  
TAVARES FL 32778-7800

PHONE: (352) 343-9839  
FAX: (352) 343-9473

[www.lakegovernment.com](http://www.lakegovernment.com)

## **ADDENDUM NO. 2**

**Date: March 1, 2012**

### **Invitation to Bid (ITB) No. 12-0212**

#### **Lake County Boiler Replacement (EECBG)**

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum with the initial bid or proposal response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid or proposal from being considered for award.

This addendum \_\_\_\_ does   X   does not change the date for receipt of bids or proposals.

The purpose of this addendum is to provide further clarifying information to all potential responding vendors in association with two specific matters that have arisen after issuance of addendum 1:

**1.** The following additional question and answer is provided:

**Question:** After looking at the addendum no. 1 on the answer to question 5 – it is stated that we must use stainless steel venting material AL29-4C. Is this based on the Patterson – Kelley boiler specs? If so, the boiler manufacturer that we are choosing to propose calls for either PVC/CPVC or Stainless. Are we able to use PVC/CPVC so long as it is manufacturer specified and meets the cat. IV venting?

**Answer:** The manufacturer's installation specifications may be followed as long as the warranty on both the boiler and the venting system are not compromised. The response in addendum 1 was based on requirements associated with the boiler identified in the ITB (see previous comment/discussion in regards to the potential for that item not to comply with the requirements of the Buy America Act).

2. It remains the vendor's responsibility to identify and provide a boiler that is compliant with the performance requirements associated with the ITB and the Buy America Act. However, in response to a vendor inquiry, vendors are advised that the HydroTherm KN10 1,000 MBH input Condensing Boiler natural gas fired is considered an acceptable product.

Firm Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_ Title: \_\_\_\_\_

Typed/Printed Name: \_\_\_\_\_